



Product Service

CERTIFICATE

No. Z2 06 02 48107 004

Holder of Certificate: Bosch Security Systems B.V.Kapittelweg 10
4827 HG Breda
THE NETHERLANDS**Production
Facility(ies):**

58811

Certification Mark:**Product:**EVAC Unit
(Public Address and Emergency Sound System)**Model(s):**

Plena Voice Alarm System V2.x

Parameters:

Rated voltage: 115 / 230 V AC

Rated frequency: 50 / 60 Hz

Protection class: I

Remark:

The final installation is not covered by this certificate. The installation of this certified product has to be carried out by a qualified and authorized company following the mentioned standards of this certificate. This must be confirmed by filling out the manufacturer's installation check list. The installer has to take special measures if non-redundant parts of the system will fail.

Tested according to:

IEC 60849:1998

IEC 60065:1998

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. See also notes overleaf.

Test report no.:

028-70099277-000

Date, 2006-02-13

Page 1 of 1

