

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0359-UKCA-CPR-00096**

Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020.

**Product(s):** Control and indicating equipment with integrated power supply  
(refer to attached appendix for details and conditions)

**placed on the market under the name or trademark of:** Tyco Fire & Security GmbH, Victor van Bruns-Strasse 21, 8212 Neuhausen Am Rheinfall (Switzerland)

**and produced in the manufacturing plant(s):** Bentel Security Srl, VIA GABBIANO, 22 CORROPOLI (TE) Italy 64013

**Intended use:** Fire Safety



0359

Approved Body (UK)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

**EN54-2:1997+A1:2006**  
**EN54-4:1997+A1:2002+A2:2006**

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **24-NOV-2022** and will remain valid as long as neither the Designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Approved Body  
0359

**Certification Officer:** Andrew Lawson

**Date:** 24-NOV-2022

**Signature:**

**Issue:** 1

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

0359-UKCA-CPR-00096

## APPENDIX 1: Certificate of Constancy of Performance 0359-UKCA-CPR-00096

The details and conditions of use for the **Control and indicating equipment with integrated power supply** placed on the market under the name or trademark of:

**Tyco Fire & Security GmbH, Victor van Bruns-Strasse 21, 8212 Neuhausen Am Rheinfall (Switzerland)**

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with **EN54-2:1997+A1:2006, EN54-4:1997+A1:2002+A2:2006:**

Model	Manufacturing Location	Product Description
J424	PI.P00083	Control and indicating equipment with integrated power supply

### Conditions of use:

Suitable for indoor applications only

### List of optional functions with requirements:

- 7.8 Output to fire alarm device
- 7.9 Output to fire alarm routing equipment
- 7.11 Delays to outputs
- 7.12 Co-incidence detection Type C
- 10 Test condition

### General notes:

1. Evaluated under Intertek project number G104737666.
2. No CE or other type approval is made or inferred outside of the Assessment and Verification of Constancy of Performance as stipulated on this certificate.