

Certificate of constancy of performance,

0832-CPR-F1151

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

ED300 Intelligent Analogue Addressable Multi-Criteria Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Produced by or for

INIM ELECTRONICS S.R.L

Via Fosso Antico snc – Fraz. Centobuchi
63076 Monteprandone (AP)
Italy

and produced in the manufacturing plant(s)

INIM ELECTRONICS S.R.L

Via Fosso Antico snc – Fraz. Centobuchi
63076 Monteprandone (AP)
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-5:2000 + A1:2002 - Heat detectors - Point detectors
EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors
EN 54-17:2005 - Short circuit isolators

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 08 February 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 08 February 2016
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR-F1151

Bases:

EB0010 Standard base
EB0020 Relay base

Sensitivities:

Meets EN 54-7:2000 with 'low', 'medium-low', 'medium-high' and 'high' sensitivities

Heat Classifications:

Meets EN 54-5:2000 at Class A1R and Class B



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 08 February 2016
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.