

## Certificate of Product Approval

Certificate Number: 991k

Issue: 01

### INIM ELECTRONICS S.R.L

Via Fosso Antico snc  
Fraz. Centobuchi  
63076 Montepandone (AP)  
Italy



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

**Control and Indicating Equipment**  
PRAESIDIA216

(refer to Appendix for details)

#### Standards

**EN 54-2:1997 + A1:2006**  
**EN 54-4:1997 + A1:2002 + A2:2006**  
**EN 54-21:2006**  
**EN 12094-1:2003**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Eman Mattie-Suleiman  
Verifier

25 November 2016  
Date of Issue

25 November 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 991k INIM ELECTRONICS S.R.L

Issue: 01

Certified Product	Description	LPCB Ref.No.
PRAESIDIA2 16	<p>2 – 16 Loop Analogue Addressable Control and Indicating Equipment and Extinguishing Control Panel (e.c.d)</p> <p>Incorporating the following modular units:            IFM24160 CAN power-supply module            IFM2L CAN module with 2 loops            IFMNET CAN module for Hornet network connection            IFM4R CAN module with 4 relays            IFM4IO CAN module with 4 I/O            IFMDIAL CAN dialler module            IFM16IO CAN module with 16 I/O            IFMLAN CAN LAN module            IFMEXT CAN extinguishant module            FPMCPU CPU module            FPMLLED LED module            FPMLLEDPRN LED module with printer            FPMEXT LED module for extinguishant module</p> <p>Optional colour variant;            PRAESIDIA216R Red Cabinet</p> <p>Incorporating the following mechanical units:            FPMNUL Blind-plate module            PRCAB Spare cabinet            PRCABR Spare Cabinet RED            PRREP Metal box for FPMCPU assembly in REPEATER configuration</p>	991k/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for LPCB

Eman Mattie-Suleiman  
Verifier

25 November 2016  
Date of Issue

25 November 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
 T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 991k INIM ELECTRONICS S.R.L

Issue: 01

Certified Product	Description	LPCB Ref.No.
	PRCABSP SPACER For back cabinet PRCABSPR SPACER For back cabinet Red Colour  Certified with the following options with requirements from EN 54-2:1997 + A1: 2002 + A2: 2006: 7.8 Output to fire alarm devices (option with requirements) 7.9.1 Output to fire alarm routing equipment (option with requirements) 7.9.2 Alarm confirmation input from fire alarm routing equipment (option with requirements) 7.10 Outputs to fire protection equipment (options with requirements) 7.10.1 Output type A (option with requirement) 7.10.2 Output type B (option with requirement) 7.10.3 Output type C (option with requirement) 7.10.4 Fault monitoring of fire protection equipment (option with requirement) 7.11 Delays to outputs (option with requirements) 7.12 Dependencies on more than one alarm signal (option with requirements) 7.12.1 Type A dependency (option with requirement) 7.12.2 Type B dependency (option with requirement) 7.12.3 Type C dependency (option with requirement) 7.13 Alarm Counter (option with requirements) 8.3 Fault signals from points (option with requirements) 8.9 Output to fault warning routing equipment(option with requirements) 9.5 Disablement of addressable point (option with requirements) 10 Test condition (option with requirements)  Certified with the following options with requirements from EN 12094-1:2003 4.17 Delay of extinguishing signal	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for LPCB

Eman Mattie-Suleiman  
Verifier

25 November 2016  
Date of Issue

25 November 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



**bre**

## Appendix to Certificate No: 991k INIM ELECTRONICS S.R.L

Issue: 01

Certified Product	Description	LPCB Ref.No.
	<p>4.18 Signal representing the flow of extinguishing agent</p> <p>4.19 Monitoring of the status of components</p> <p>4.20 Emergency hold device</p> <p>4.21 Control of flooding time</p> <p>4.22 Initiation of secondary flooding</p> <p>4.24 Triggering signals to equipment within the system</p> <p>4.26 Triggering of equipment outside the system</p> <p>4.27 Emergency abort device</p> <p>4.28 Control of extended discharge</p> <p>4.29 Release of the extinguishing media for selected flooding zones</p> <p>4.30 Activation of alarm devices with different signals</p> <p>Notes:</p> <ol style="list-style-type: none"> <li>1. Scope of approval does not include the operation of the network functionality.</li> <li>2. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13.</li> <li>3. The e.c.d is approved to EN12094-1 for more than 1 flooding zone when 2 FPMCPU modules are used.</li> <li>4. The CIE is also approved when connected with FPMCPU as a CPU /Repeater module.</li> </ol>	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Eman Mattie-Suleiman  
Verifier

25 November 2016  
Date of Issue

25 November 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)


