

# **BRE Global Limited & LPCB**

*Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX*

*Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk*

## **EC-CERTIFICATE OF CONFORMITY**

### **0832 - CPD - 1071**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### **VW2W100 wire to wireless translator module for use in fire detection and alarm systems**

*(For conditions of use for the product see the attached appendix)*

placed on the market by

**Argus Security S.r.l.,  
Via G M Ferrario 24, 20041 Agrate Brianza, Milan, Italy**

and produced in the factory

**Argus Security S.r.l.  
Via Josip Ressel 2/7, S Dorligo della Valle, 34018 Trieste, Italy**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Global Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

**EN 54 - 18: 2005 - Input/output devices  
EN 54 - 17: 2005 - Short circuit isolators  
EN 54 - 25: 2008 - Components using radio links**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 21/12/2010 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Eman Mattie-Suleiman  
Certification Manager  
For and on behalf of BRE Global Limited

Date of Issue: 21/12/2010  
Issue Number: 1  
Page: 1 of 2

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.  
To check the authenticity of this certificate, please visit our website or contact us.

## **BRE Global Limited & LPCB**

*Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX*

*Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk*

### **Appendix to EC Certificate of conformity 0832 - CPD - 1071**

The details and conditions of use for the VW2W100 wire to wireless translator module, placed on the market by Argus Security S.r.l., Via G M Ferrario 24, 20041 Agrate Brianza, Milan, Italy are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):



Eman Mattie-Suleiman  
Certification Manager  
For and on behalf of BRE Global Limited

Date of Issue: 21/12/2010

Issue Number: 1

Page: 2 of 2

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.