



UQGS.S480 Heat-automatic Fire Detectors

Page Bottom

Heat-automatic Fire Detectors

See General Information for Heat-automatic Fire Detectors

PROTECTOWIRE CO INC
60 WASHINGTON ST
PEMBROKE, MA 02359-1833 USA

S480

Programming module, Model(s) CTMP-1 (h)

Interface module, Model(s) CTM-530 (f), CTM-530E (f) (d), CTM-530LT (f), CTM-530LTE (f) (d), PIM-530 (g), PIM-530E (d) (g), PIM-530LT (g), PIM-530LTE (d) (g)

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
CTI-XXX, CTI-XXXR, CTI-XXXX (c)						
	HSC	D4	-	See footnote c	50	25
EPC (a)(2), EPN (a)(2), EPR (a)(2), XCR (a)(2)						
	FT	None	-	155-190-220-280-356	50	25
PLR (b)(2)	FT	None	-	155-190-220-280-356	50	25
PLR-R (b)(2)	FT	None	-	155-190-220-280	50	25
PLR-X (b)(1)	FT	None	-	140	50	25
PTS-8101	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
				135 - 235	50	25
				135 - 235	50	25
PTS-8102	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8103	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8104	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8106	FT/ROR, HSC	D4	NO/NC	135-235	50	25
PTS-8108	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
				135 - 235	50	25
PTS-8110	FT/ROR, HSC	D4	NO/NC	135-235	50	25
PTS-8201	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8202	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8203	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8204	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8206	FT/ROR, HSC	D4	NO/NC	135-235	50	25
PTS-8208	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8301	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8302	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8303	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8304	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25

PTS-8308	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8401	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8402	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8403	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8404	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
PTS-8406	FT/ROR, HSC	D4	NO/NC	135-235	50	25
PTS-8408	FT/ROR, HSC	D4	NO/NC	135 - 235	50	25
XLT (a)(1)	FT	None	-	135	50	25

D4 - For connection to any manufacturer's Listed compatible control unit.

HSC - Heat sensitive cable

FT - Fixed temperature

FT/ROR - Fixed temperature/rate of rise combination

(1) - To be used in ambient temperatures between -60°F (-51°C) and 100°F (38°C).

(2) - Cables rated (155 F) are not to be used in ambient temperatures exceeding (100 F) degrees. And when cables rated (190 F) are to be used in ambient temperatures exceeding (150 F) degrees. Cables rated (280 F) are not to be in ambient temperatures exceeding (221 F) degrees.

(a) - Resistance approximately 20 ohms per 100 ft of cable.

(b) - Resistance approximately 5 ohms per 100 ft of cable.

c - Where XXX represents the temperature rating, ordinary (155°F), intermediate (190°F and 220°F), high (280°F) and extra high (356°F) rating. All models can have the suffix ?M which represents the models with high tensile strength stainless steel wire, which is wound around the Detector

d - Suitable for outdoor use.

f - For use with Linear Heat Detector, model CTI-XXX, CTI-XXXX, and CTI-XXXX

g - For use with Linear Heat Detectors, model EPC, EPR, XCR, and PLR

h - For use with Interface module, model CTM-530LT, CTM-530LTE, PIM-530LT, and PIM-530LTE.

Note - Protectowire fire detecting wire, fixed temperature type having two conductors, electrically insulated from each other with a thermo-responsive plastic. When subjected to heat from a fire, the conductors make contact with each other thereby closing an electrical circuit. For use in signal circuits 30 V , ac or 42.4 V, dc 1 amp or less. Standard Type (Cotton braided outer jacket). Temperature ratings: Ordinary (135 F, 155 F) intermediate (190 F), high (280 F) and extra high (356 F) degrees.

Last Updated on 2018-01-22

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".